

MICROBIOLOGY REPORT



LMS TECHNOLOGIES, INC.

6423 Cecilia Circle
Bloomington, MN 55439 USA

Tel: 952-918-9060
Fax: 952-918-9061

Date: May 12, 2022
Test Requested By: Authority brands
Test Type: Multi-Pass Efficiency

Scope

Customer provided three units for multi-pass efficiency testing with MS-2 bacteriophage (ATCC 15597-B1) as the challenge aerosol. Testing was performed in a 1007 ft³ chamber connected to ASHRAE type duct. Flow rate through the duct was 1200 cfm.

Method

MS-2 bacteriophage was harvested and titrated to 7.5E8 pfu/ml. Suspensions of the organisms were then aerosolized into the chamber using a nebulizer prior to powering the test device. The test chamber air was sampled at 5-minute intervals using a SKC BioStage cascade impactor for 1-minute sampling periods. The cascade impactors were calibrated to an airflow rate of 28.3 liters/min and the sampling inlet was situated at the midpoint of the test chambers. The recovered organisms were enumerated after 24-hours of incubation.

$$\text{Corrected Removal Efficiency} = 1 - \left(\frac{\text{DevicePFU}_{t=x}}{\text{DevicePFU}_{t=0}} * \frac{\text{EmptyPFU}_{t=0}}{\text{EmptyPFU}_{t=x}} \right)$$

Air Cleaner Information

Manufacturer: Aerus
Model: A1013P
Serial Number: X201445M



Figure 1: Aerus Air Scrubber

Manufacturer: PremierOne
Model: OxyQuantum



Figure 2: PremierOne OxyQuantum P1)

Manufacturer: RGF
Model: REME-LED
Serial Number: R1WRLED015



Figure 3: RGF REME-LED



Equipment

1007 ft³ Stainless-Steel Test Chamber
SKC BioStage Single-Stage Impactors
Ozone Analyzer


Data

Natural Decay													
Time	0	5	10	15	20	30	45	60					
#1	156	108	93	60	44	0	33	26	18				
#2	185	119	101	62	39	0	38	29	19				
#3	172	117	105	69	36	0	33	25	20				
PHC #1	197.7	125.9	105.8	65	46.6	0	34.4	0	0	26.8	0	0	18.4
PHC #2	248.4	141.2	116.4	67.4	41	0	40	0	0	30.1	0	0	19.4
PHC #3	224.8	138.4	121.8	75.7	37.8	0	34.4	0	0	25.8	0	0	20.5
ln(ct/c0)	0	-0.5035	-0.668	-1.1706	-1.6771		-1.8191			-2.0934			-2.443
Positive Hole Corrected Average	223.633	135.167	114.667	69.3667	41.8		36.2667			27.5667			19.4333

P1												
Time	0	5										
#1	175	4	0	0	0	0	0	0	0	0	0	0
#2	157	5	0	0	0	0	0	0	0	0	0	0
#3	177	11	0	0	0	0	0	0	0	0	0	0
PHC #1	230.2	4	0	0	0	0	0	0	0	0	0	0
PHC #2	199.4	5	0	0	0	0	0	0	0	0	0	0
PHC #3	233.7	11.1	0	0	0	0	0	0	0	0	0	0
ln(ct/c0)	0	-3.4965										
Positive Hole Corrected Average	221.1	6.7										

Time	0	5										
Efficiency %	0	94.99										

Chamber Volume (ft ³)	CADR
1007	602.79




Natural Decay													
Time	0	5	10	15	20	30	45	60					
#1	156	108	93	60	44	0	33			26		18	
#2	185	119	101	62	39	0	38			29		19	
#3	172	117	105	69	36	0	33			25		20	
PHC #1	197.7	125.9	105.8	65	46.6	0	34.4	0	0	26.8	0	0	18.4
PHC #2	248.4	141.2	116.4	67.4	41	0	40	0	0	30.1	0	0	19.4
PHC #3	224.8	138.4	121.8	75.7	37.8	0	34.4	0	0	25.8	0	0	20.5
ln(ct/c0)	0	-0.5035	-0.668	-1.1706	-1.6771		-1.8191			-2.0934			-2.443
Positive Hole Corrected Average	223.633	135.167	114.667	69.3667	41.8		36.2667			27.5667			19.4333

RGF													
Time	0	5	10	15	20	30	45	60					
#1	136	58	47	28	25	0	22			14		11	
#2	130	58	51	33	21	0	21			18		8	
#3	128	53	55	35	20	0	18			9		9	
PHC #1	166.2	62.6	50	29	25.8	0	22.6	0	0	14.2	0	0	11.1
PHC #2	157.2	62.6	54.6	34.4	21.6	0	21.6	0	0	18.4	0	0	8.1
PHC #3	154.2	56.8	59.2	36.6	20.5	0	18.4	0	0	9.1	0	0	9.1
ln(ct/c0)	0	-0.9648	-1.0701	-1.5636	-1.9507		-2.032			-2.4383			-2.8259
Positive Hole Corrected Average	159.2	60.6667	54.6	33.3333	22.6333		20.8667			13.9			9.43333

Time	0	5	10	15	20	30	45	60				
Efficiency %	0	36.95	33.11	32.5	23.94	19.18	29.17	31.81				

Chamber Volume (ft^3)	CADR
1007	1.83




Natural Decay													
Time	0	5	10	15	20	30	45	60					
#1	156	108	93	60	44	0	33	26	18				
#2	185	119	101	62	39	0	38	29	19				
#3	172	117	105	69	36	0	33	25	20				
PHC #1	197.7	125.9	105.8	65	46.6	0	34.4	0	0	26.8	0	0	18.4
PHC #2	248.4	141.2	116.4	67.4	41	0	40	0	0	30.1	0	0	19.4
PHC #3	224.8	138.4	121.8	75.7	37.8	0	34.4	0	0	25.8	0	0	20.5
ln(ct/c0)	0	-0.5035	-0.668	-1.1706	-1.6771	-1.8191	-2.0934	-2.443					
Positive Hole Corrected Average	223.633	135.167	114.667	69.3667	41.8	36.2667	27.5667	19.4333					

Aeras													
Time	0	5	10	15	20	30	45						
#1	213	61	24	12	5	0	1	0					
#2	200	75	26	9	6	0	1	0					
#3	233	76	22	11	4	0	5	1					
PHC #1	304.2	66.2	24.8	12.2	5	0	1	0	0	1	0	0	0
PHC #2	277.3	83	26.8	9.1	6	0	1	0	0	0	0	0	0
PHC #3	349.4	84.3	22.6	11.1	4	0	5	0	0	1	0	0	0
ln(ct/c0)	0	-1.383	-2.5294	-3.358	-4.1281	-4.8902	-6.143						
Positive Hole Corrected Average	310.3	77.8333	24.7333	10.8	5	2.33333	0.66667						

Time	0	5	10	15	20	30	45
Efficiency %	0	58.5	84.45	88.78	91.38	95.36	98.26

Chamber Volume (ft^3)	CADR
1007	83.95






Figure 4: MS-2 Pfu at 0 min and 5 min (P1)




Figure 5. Ozone data for all tests